# Errata for 2015 Uniform Plumbing Code – 1st Printing

The following is a change that we found after the first printing of the 2015 Uniform Plumbing Code. This change may or may not apply to your code book. However, we do encourage you to check your code book with this list to ensure that all the changes are updated. Thank you.

## Appendix C

**Table C 304.2** Revise the fixture unit value in the table for 12 inch pipe at  $\frac{1}{16}$  slope. Table shows 2900 fixture units to 3900 fixture units in accordance with ASPE Handbook.

TABLE C 304.2
BUILDING DRAINS AND BUILDING SEWERS<sup>1</sup>

DIAMETER OF PIPE (inches)	MAXIMUM NUMBER OF DRAINAGE FIXTURE UNITS FOR SANITARY BUILDING DRAINS AND RUNOUTS FROM STACKS  SLOPE (inches per foot)			
	2	_	_	21
21/2	_	_	24	31
3	_	20	42 <sup>2</sup>	50 <sup>2</sup>
4	_	180	216	250
5	_	390	480	575
6	_	700	840	1000
8	1400	1600	1920	2300
10	2500	2900	3500	4200
12	3900	4600	5600	6700
15	7000	8300	10 000	12 000

For SI units: 1 inch = 25 mm, 1 inch per foot = 83.3 mm/m

#### Notes:

04/01/15

# Chapter 17

**Section 1701.1** Revise Section 1701.1 to add a solid vertical line in the margin to indicate a technical change has occurred from the 2012 UPC edition.

# CHAPTER 17 REFERENCED STANDARDS

### 1701.0 General.

**1701.1 Standards.** The standards listed in Table 1701.1 are intended for use in the design, testing, and installation of materials, devices, appliances, and equipment regulated by this code.

These standards are mandatory where required by sections in this code.

Organization abbreviations referred to in Table 1701.1 are defined in a list found at the end of the table.

10/22/15

<sup>&</sup>lt;sup>1</sup> On-site sewers that serve more than one building shall be permitted to be sized according to the current standards and specifications of the administrative authority for public sewers.

<sup>&</sup>lt;sup>2</sup> A maximum of two water closets or two bathroom groups, except in single-family dwellings, where a maximum of three water closets or three bathroom groups shall be permitted to be installed.