

Errata for 2021 National Standard Plumbing Code – 1st Printing

The following is a change that we found after the first printing of the *2021 National Standard Plumbing Code*. We do encourage you to make a note in your code book to ensure that the change is reflected. Thank you.

SECTION: 2.12 Sleeves for Piping

Paragraph a.) should read as follows:

a. A piping passing through concrete walls, floor, slabs, and masonry walls shall be provided with sleeves for protection. EXCEPTION: Sleeves shall not be required for pipes passing through drilled or bored holes. Such holes shall provide ~~1-1/2~~ 1/2 inch minimum clearance around the pipe and any thermal insulation.

TABLE 10.19: Sizing of Residential Water Softeners

Correct the number of bathroom groups served to the following:

Required Size of Softener Connection (in.)	Number of Bathroom Groups Served ¹
3/4	Up to 22 2 ²
1	Up to 43 4 ³

Updated 9/4/2024