

## Errata for 2012 Uniform Plumbing Code – 6th Printing

The following is a change that we found after the sixth printing of the 2012 Uniform Plumbing Code. This change may or may not apply to your code book. However, we do encourage you to check your code book with this list to ensure that all the changes are updated. Thank you.

### Appendix C

**Table C 5.3** Revise the fixture unit value in the table for 12 inch pipe at 1/16 slope. Table shows 2900 fixture units to 3900 fixture units in accordance with ASPE Handbook.

<b>TABLE C 5.3 BUILDING DRAINS AND BUILDING SEWERS<sup>1</sup></b>				
<b>DIAMETER OF PIPE (inches)</b>	<b>MAXIMUM NUMBER OF DRAINAGE FIXTURE UNITS FOR SANITARY BUILDING DRAINS AND RUNOUTS FROM STACKS</b>			
	<b>SLOPE (inches per foot)</b>			
	$\frac{1}{16}$	$\frac{1}{8}$	$\frac{1}{4}$	$\frac{1}{2}$
2	–	–	21	26
2½	–	–	24	31
3	–	20	42 <sup>2</sup>	50 <sup>2</sup>
4	–	180	216	250
5	–	390	480	575
6	–	700	840	1000
8	1400	1600	1920	2300
10	2500	2900	3500	4200
12	3900	4600	5600	6700
15	7000	8300	10 000	12 000

For SI units: 1 inch = 25 mm, 1 inch per foot = 83.3 mm/m

Notes:

- <sup>1</sup> On-site sewers that serve more than one building shall be permitted to be sized according to the current standards and specifications of the administrative authority for public sewers.
- <sup>2</sup> A maximum of two water closets or two bathroom groups, except in single-family dwellings, where a maximum of three water closets or three bathroom groups shall be permitted to be installed.

12/30/2014