

Errata for the  
 2014 Oregon Plumbing Specialty Code

~~Strikethrough~~ text represents deleted language.

Underlined text represents added language.

**Chapter 6,**

**603.4.16 Protection from Fire systems.** Except as provided under Section ~~603.4.15.1 and 603.4.15.2~~ 603.4.16.1 and 603.4.16.2...

**Chapter 7,**

**Table 7-5:**

TABLE 7-5  
 MAXIMUM UNIT LOADING AND MAXIMUM LENGTH OF DRAINAGE AND VENT PIPING

SIZE OF PIPE (inches)	1 ¼	1 ½	2	2 ½	3	4	5	6	8	10	12
<b>Maximum Units</b>											
Drainage Piping <sup>1</sup>											
Vertical	1	2 <sup>2</sup>	16 <sup>3</sup>	32 <sup>3</sup>	48 <sup>4</sup>	256	600	1,380	3,600	5,600	8,400
Horizontal	1	<u>2<sup>2</sup></u>	8 <sup>3</sup>	14 <sup>3</sup>	35 <sup>4</sup> <u>5</u>	216 <sup>5</sup>	428 <sup>5</sup>	720 <sup>5</sup>	2,640 <sup>5</sup>	4,680 <sup>5</sup>	8,200 <sup>5</sup>

**715.1 Materials.** The building sewer, beginning ~~2 feet (610 mm)~~ 5 feet (1524 mm) from a building or structure, shall be of such materials as prescribed in this code.

**Table 7-7:**

TABLE 7-7  
 MINIMUM HORIZONTAL DISTANCE REQUIRED FROM BUILDING SEWER

Buildings or structures <sup>1</sup>	<del>2</del> <u>5</u>
--------------------------------------	-----------------------

**723.2** Where circumstances exist that make air and water tests described in Section 712.2 and Section 712.3 impractical, see Section ~~103.5.6.3~~ 103.5.3.3.

**Chapter 11,**

**1101.3 Material Uses....**

Exterior storm drainage piping and fittings ~~shall~~ may be CPE as listed in Table 14-1.

## Chapter 13,

**1310.26 Piped Vacuum System-Category 3.** Add the reference: [\[NFPA 99:3.3.23\]](#)

**1310.27 Compressed Air System-Category 3.** Add the reference: [\[NFPA 99:3.3.22\]](#)

**1311.1.2 Materials.** In those portions of systems intended to handle oxygen or nitrous oxide at gauge pressures of less than 350 pounds-force per square inches (psi) (2,068 kPa), material construction shall be compatible with oxygen under the temperatures and pressures to which the components can be exposed in the containment and use of oxygen, nitrous oxide, mixtures of these gases, or mixtures containing more than 23.5 percent oxygen. ~~[NFPA 99:5.1.3.4.4(2)]~~ [\[NFPA 99: 1.3.5.4\]](#)

### **1319.5 Flux....**

~~Short~~ [Where](#) sections of copper tube shall be brazed onto the noncopper component and the interior of the subassembly...

**1320.3 Future Piping.** Shutoff valves provided for the connection of future piping shall meet the following requirements:

- (1) [They shall](#) be locked in a restricted area
- (2) [They shall](#) be locked or latched closed
- (3) [They shall](#) be identified in accordance with Section 1323.2 [NFPA 99:5.1.4.10]

**1320.4.2 Labeled.** The source valve shall be labeled in accordance with Section ~~1323.1~~ [1323.3](#).

**1320.5.3 Labeled.** The main line shall be labeled in accordance with Section ~~1323.2~~ [1323.3](#).

**1325.5 Medical air Compressors...** ~~[NFPA 99:5.1.3.5.11.1]~~

**1329.8** Inspection and testing shall be performed on all new gas and vacuum systems, additions, renovations, temporary installations, or repaired systems. ~~[NFPA99:5.3.12]~~ [\[NFPA 99:53.9.1.1\]](#)