

**From:** [Alma Ramos](#)  
**To:** [IAPMOSD-2027wetc@ConnectedCommunity.org](mailto:IAPMOSD-2027wetc@ConnectedCommunity.org)  
**Cc:** [codes-dept](#)  
**Subject:** 2025 WESTAND ROP Third Circulation of Negative Comments  
**Date:** Wednesday, August 20, 2025 10:21:22 AM  
**Attachments:** [image004.png](#)  
[2025 WESTAND ROP Third Circulation of Comments.pdf](#)  
**Importance:** High

---

Dear WESTAND Technical Committee Members,

In accordance with Section 5.6 of the Regulations Governing Consensus Development of the Water Efficiency and Sanitation Standard, I have attached the additional negative comments received after the second recirculation period to allow the committee the opportunity to review the comments.

The ballot material for the subject documentation is now available on the KAVI site at:  
<https://kavi.iapmo.org/higherlogic/ws/groups/28fd25e1-9e1f-493a-92c9-018ed33e7cfc/ballots>

The additional negatives received are for Items #[008](#), [038](#), [085](#), and [104](#). Therefore, these items will be reopened to allow the committee the opportunity to review the comments.

**If you do not wish to change your vote, no action is required.** However, if you wish to change your vote after review of comments, you may do so by **Tuesday, August 26, 2025, at 5:00 PM (PT)**. Any affirmative voters can change their vote.

If you wish to change your vote [negative] or indicate [abstain] please provide your comments by replying to this email or submitting on Kavi.

Thank you for your willingness to serve on this committee.

***Alma Ramos***

Sr. Manager of Codes and Standards  
IAPMO World Headquarters  
4755 E. Philadelphia Street  
Ontario, CA 91761  
Office (909) 230-5528  
Email: [alma.ramos@iapmo.org](mailto:alma.ramos@iapmo.org)

## 2025 WESand ROP Third Circulation of Comments

<b>Ballot Name:</b>	<b>WESand Item #008</b>	
<b>Voter Name</b>	<b>Vote</b>	<b>Comments</b>
Kendzel, Jim	NEGATIVE w/comment	It is hard to argue with John Koeller on this one. He has convinced me to change my vote.

<b>Ballot Name:</b>	<b>WESand Item #038</b>	
<b>Voter Name</b>	<b>Vote</b>	<b>Comments</b>
Ribbs, Phil	NEGATIVE w/comment	I agree with Chuck White's comments. Also, more clarification is needed on these systems.
Tseng, Aster	NEGATIVE w/comment	I agree with Chuck White's comments. More clarification is needed.

<b>Ballot Name:</b>	<b>WESand Item #085</b>	
<b>Voter Name</b>	<b>Vote</b>	<b>Comments</b>
PREMER, DAMON	NEGATIVE w/comment	I agree with Edward Osann.

<b>Ballot Name:</b>	<b>WESand Item #104</b>	
<b>Voter Name</b>	<b>Vote</b>	<b>Comments</b>
PREMER, DAMON	NEGATIVE w/comment	I agree with Laura Allen.
Ribbs, Phil	AFFIRMATIVE	Remove the vent and the air admittance valve (AAV) which is not needed or required. Verify that the one inch discharge pipe to the outside is adequately sized. San Jose Valley Water District does not promote this type of system, nor do they have the authority to allow the system. The allowance and approval of any system of this type can only be approved by the AHJ.
Sovocool, Kent	NEGATIVE w/comment	I feel Laura Allen advances excellent points and the impact on utility conservation programs cannot be ignored.