

Technical Committees Formal Interpretations Request/Ballot Form

- Interpretation requests must pertain to the IAPMO Plumbing or Mechanical Code(s) or their appendices, except Appendix I of the UPC.
- Return completed form to:
**IAPMO Council Secretary–
Interpretations
5001 E. Philadelphia St.
Ontario, CA 91761-2816.**
- Please read carefully instructions on reverse side.
- Please allow a minimum of 90 days for ballot results

Check One Only	
<input checked="" type="checkbox"/> UPC 2003	<input checked="" type="checkbox"/> UPC 2006

Question _____

PLEASE PRINT

Phrase question and presumed correct answer in a definitive form requiring no more than a "YES" or "NO" response. Attach additional sheets, if necessary.

Section 405.4 of the 2003 UPC and Section 404.4 of the 2006 UPC states that an approved wye or other directional type branch fittings shall be installed in all continuous wastes connection or receiving the discharge from waste disposal units, dishwashers, clothes washers, or other force discharge fixtures or appliances. Do these sections permit the use of a sanitary tee installed in a vertical position on the continuous waste to be considered a "directional type branch fitting"?

Signed _____ **Signature on file** _____

For Technical Committee Use ONLY

In response to applicant's answer to question posed, please check Yes or No.

YES

NO

Print Name: _____

Date: _____

Signature: _____

Comments:

Sanitary tee shall not be used as a directional fitting in the continuous waste.